
New Lenox School District 122

**Public Notice for
Request for Proposals
for a Guaranteed Energy
Savings Contract Project**

Addendum 2 –

April 20,2020

New Lenox School District 122
102 S. Cedar Rd.
New Lenox, Illinois 60451

April 20, 2020

Answers to Questions from Pre-Proposal Meeting: Addendum 2 – 04.20.20

- 1) About how many device licenses will be required for each JACE unit (how many devices will be controlled by each JACE)? **For potential future expansion purposes, all JACEs should have the maximum device limit (JACE 8200)**
- 2) What kind of Supervisor do we have now (what will these devices be linked to) (Make, model)? **Tridium N4 server**
- 3) Do we have Automated Logic Controls / Schneider. **The district's preference is Schneider Electric I/A series controls**
- 4) Does the District have access and passwords to the controls. **Yes, access and passwords can be given to the successful respondent**
- 5) Do you happen to know if the existing JACE units are R2 or AX? If AX, do you know if the existing protocol is obix, bacnet, or lon? **The existing JACEs to be replaced are R2 with lon**

Spencer Pointe, Spencer Crossing and Spencer Trail building drawings:

Please email Robert Groos at Rgroos@nlsd122.org for the link.

Historical energy data for Spencer Campus schools:

Please email Robert Groos at Rgroos@nlsd122.org for a copy of this information.

NLSD122 building square footage data:

Please email Robert Groos at Rgroos@nlsd122.org for a copy of this information.

