

---

# **New Lenox School District 122**

**Public Notice for  
Request for Proposals  
for a Guaranteed Energy  
Savings Contract Project**

**Addendum 1 –**

**April 10, 2020**

---

**New Lenox School District 122**  
102 S. Cedar Rd.  
New Lenox, Illinois 60451

April 10, 2020

---

## **SCOPE OF SERVICES Clarification Addendum 1 – 04.10.20**

The original language in the RFP document indicates that work is to be focused on the “Spencer Campus” only. Please note that Cherry Hill is listed out in the detail because Cherry Hill is a replica of Spencer Trail and any Spencer Trail recommendations could easily be replicated at Cherry Hill.

Please also note that the replacement of the JACE units mentioned in the original scope language need to take place at Spencer Pointe, Spencer Crossing, Spencer Trail, Oster-Oakview, and Arnold J Tyler. Specifically; the District needs BAS upgrades at these schools including new Tridium JACE 8 universal network controllers running the most current revision of Niagra N4. The vendor needs to also integrate the new universal network controllers into the existing Tridium N4 Web Supervisor. There are a total of 8 new JACE units required: Pointe/Crossing (3), Oster-Oakview (1), Trail (1), Tyler (1).

*Original Language in April 10, 2020 RFP Document:*

*Scope of Facility Audit/Services will include Respondents' proposed energy and operational cost saving measures as defined in Section I, paragraph C.1 of this RFP for baseline opportunities including improvements with the possibility of multiple phases. The main focus of these phases include re-commissioning and re-scheduling existing HVAC systems, replacing existing gymnasium lighting, limited control upgrades including replacement of JACE units, removal and replacement of cooling equipment and possible solutions regarding humidity control. All work is to be focused on the “Spencer Campus” only (Pointe/Crossing/Trail/Cherry Hill).*

