NUMBER0	TINWSYS.NAME	DENTIFICATION_C	DESCRIPTION_TEXT	LLLECTION_END_T	_ASGN_IDENT_C	TSAANLYT.NAME	Nov. 21	Oct. 21	21-Jun	UOM_CODE
IL1977910	CORRECTIONAL	LP2J023	CONTROL CENTER BATH	29-Nov-21	DISTRIBUTION	LEAD	86.4	28.3	0	UG/L
IL1977910	CORRECTIONAL	LP2J047	VISITOR'S CENTER BATHROOM	29-Nov-21	DISTRIBUTION	LEAD	22.7	35.9	3.95	UG/L
IL1977910	CORRECTIONAL	LP2J044	ROLL CALL RM. BATHROOM	29-Nov-21	DISTRIBUTION	LEAD	21.6	8.09	2.27	UG/L
IL1977910	CORRECTIONAL	LP3S003	ADMINISTRATION BLDG	29-Nov-21	DISTRIBUTION	LEAD	19.2	14.9	4.59	UG/L
IL1977910	CORRECTIONAL	LP2J046	MSU INMATE VISITING BATHROOM	29-Nov-21	DISTRIBUTION	LEAD	15.8	30.6	3.79	UG/L
IL1977910	CORRECTIONAL	LP3S002	PC VISITING ROOM	29-Nov-21	DISTRIBUTION	LEAD	12.9	0	11.5	UG/L
IL1977910	CORRECTIONAL	LP2J035	NRC LOBBY BATHROOM	29-Nov-21	DISTRIBUTION	LEAD	6.83	128	0	UG/L
IL1977910	CORRECTIONAL	LP2J026	NRC REC. DOCK BATHR	29-Nov-21	DISTRIBUTION	LEAD	5.63	366	0	UG/L
IL1977910	CORRECTIONAL	LP2J027	NRC MAINT. PLUM. SHO	29-Nov-21	DISTRIBUTION	LEAD	4.31	39.5	0	UG/L
IL1977910	CORRECTIONAL	LP2J036	NRC REFRIGERATION SHOP	29-Nov-21	DISTRIBUTION	LEAD	3.89	3.67	2.6	UG/L
IL1977910	CORRECTIONAL	LP3R020	TRAINING SCHOOL	29-Nov-21	DISTRIBUTION	LEAD	3.49	5.68	5.05	UG/L
IL1977910	CORRECTIONAL	LP2J048	NEW POWER HOUSE BATHROOM	29-Nov-21	DISTRIBUTION	LEAD	3.3	11.7	0	UG/L
IL1977910	CORRECTIONAL	LP3R019	CHIEF ENGINEER OFFIC	29-Nov-21	DISTRIBUTION	LEAD	2.81	3.86	2.49	UG/L
IL1977910	CORRECTIONAL	LP3R013	MAINTANENCE SHOP	29-Nov-21	DISTRIBUTION	LEAD	2.77	0	0	UG/L
IL1977910	CORRECTIONAL	LP2J028	NRC MAIN BOILER RM.	29-Nov-21	DISTRIBUTION	LEAD	0	0	0	UG/L
IL1977910	CORRECTIONAL	LP2J039	MOTOR POOL BATHROOM	29-Nov-21	DISTRIBUTION	LEAD	0	3.91	2.74	UG/L
IL1977910	CORRECTIONAL	LP2J051	MSU ELECTRICIAN ROOM	29-Nov-21	DISTRIBUTION	LEAD	0	0	0	UG/L
IL1977910	CORRECTIONAL	LP2J038	NRC LOCKSMITH OFFICE SINK	29-Nov-21	DISTRIBUTION	LEAD	0	2.23	5.57	UG/L
IL1977910	CORRECTIONAL	LP2J025PROBL	NRC NEW POWERHOUS	29-Nov-21	DISTRIBUTION	LEAD	0	0	0	UG/L
IL1977910	CORRECTIONAL	LP2J025	NRC OFFICERS DINNING	29-Nov-21	DISTRIBUTION	LEAD	0	226	3.71	UG/L