

Constantino, Mike

From: Gudgel, Jody
Sent: Monday, June 18, 2012 11:00 AM
To: Constantino, Mike
Subject: FYI
Attachments: scan0001.pdf

Mike,

They sent us a letter regarding the physical environment of their building not being able to meet licensure requirements. Because they are only a single specialty they wanted some exceptions to the requirements. Here's our response.

j

Jody Gudgel, Administrative Assistant
Division of Life Safety and Construction
Design & Construction Section
Illinois Department of Public Health
525 West Jefferson Street, 4th Floor
Springfield, IL 62761
217-785-4264 (phone)
217-782-0382 (fax)
dph.design.standards@illinois.gov (Unit email)





Pat Quinn, Governor

525-535 West Jefferson Street • Springfield, Illinois 62761-0001 • www.idph.state.il.us

June 18, 2012

Dr. W. Paul Dmowski
The IVF Surgery Center at RMI
2425 W. 22nd Street, Ste 102
Oak Brook, IL 60523

Dear Dr. Dmowski:

We received your correspondence regarding your pending CON for a single specialty ambulatory surgical treatment center. The IL Admin. Code Section 205.1360 Clinical Facilities c) Procedure rooms – Non-sterile area, allows for exceptions on clinical facilities for laser rooms and Gastrointestinal endoscopy rooms. It also allows for exceptions for pregnancy termination centers, Subpart G: Limited Procedure Specialty Centers.

If your specialty does not fall within these three categories you will be required to meet all the requirements of the ambulatory surgical treatment center.

If you have any questions regarding this matter, please feel free to contact our office at 217-785-4264. The Department's TTY number is 800-847-0566, for use by the hearing impaired.

Sincerely,

A handwritten signature in black ink, appearing to read "Henry Kowalenko". The signature is written in a cursive style.

Henry Kowalenko, Acting Division Chief
Division of Life Safety and Construction

Improving public health, one community at a time

printed on recycled paper