



STATE OF ILLINOIS
HEALTH FACILITIES AND SERVICES REVIEW BOARD

525 WEST JEFFERSON ST. • SPRINGFIELD, ILLINOIS 62761 • (217) 782-3516 FAX: (217) 785-4111

July 30, 2013

EMAIL

Janet L. Scheuerman
CON Consultant to UnityPoint Health Rock Island
PRISM Healthcare Consulting

Re: 12-101 – Trinity Rock Island

Dear Ms. Scheuerman:

Thank you for your correspondence dated July 17, 2013. Your letter describes changes which you consider necessary to report to the Illinois Health Facilities and Services Review Board (“State Board”) but which do not require the approval of the State Board. It is the opinion of the State Board Staff that the proposed replacement of the 1,500 KVA transformer with a 3,000 KVA transformer is a non-clinical expenditure that requires notice to the State Board, but does not require approval.

Based on the information you provided, these alterations have been appropriately reported to the State Board. This determination is made in accordance with Section 1130.750 of the Board’s Administrative Rules.

Your letter and this response will be added to the project file. The rules referenced above are available at the State Board website, <http://hfsrb.illinois.gov/>

If you have any questions please contact Mike Constantino or George Roate at 217.785.1557 or at Mike.Constantino@illinois.gov or George.Roate@illinois.gov.

Sincerely,

A handwritten signature in cursive script that reads "Courtney R. Avery".

Courtney R. Avery
Administrator
Illinois Health Facilities and Service Review Board